



AURANGABAD MUNICIPAL CORPORATION

FIRE BRIGADE

TELEPHONE NO-2334000-40 FAX No-2331444

Outward No:AMC/FIRE / 2022

Date 23 / 03 /2022

To,
Principal, Jito School The Joint Venture
The Delhi Public School Society
Gut No. 59/P, Shernapur Ta & Dist. Aurangabad.

Sub:- Fire NOC Renwaled is issued to Principal, Jito School The Joint Venture, The Delhi Public School Society, Gut No. 59/P, Shernapur Ta & Dist. Aurangabad.

Ref:- 1) Your letter dated 23/02/2019 2) Provisional Fire Noc dated 23/02/2019
3) Your Letter dated 23/03/2022 4) CFO Inspection dated 23/03/2022

With Reference to the above subject Fire NOC Renwaled is issued to Principal, Jito School The Joint Venture, The Delhi Public School Society, Gut No. 59/P, Shernapur Ta & Dist. Aurangabad. Plot area is 19909.00 sq mtr

Sr. No	Name of Building	Height of Building	Bild No.	No of floors	Total Area of Plot	Built/up area	Fire Noc Fees	Total Rs.
1	School Building	10.00 Mtr.	1	G + 2 Floors	19909.00 Sq.Mtr.	6412.23 Sq.Mtr.	15000	15000

Following Fire prevention and Fire protection & Fire Fighting measures subject to The School Building is provided.

1. 4.50 Mtr./6.00 Mtr. Open space all around the building is provided for the movement of fire tender and which will carry 25 tons. weight capacity.
2. Under ground 10000 lit overhead water tank 20000 lit capacity with the fire pump 900 LPM - 01 Nos of suitable capacity for building is provided.
3. Fire service inlet 2 way incoming shall be provided.
4. Main Staircase 2.00 Mtr. & Fire Escape Staircase of 1.50 mtr. Width is provided.
5. 03 Nos. having outlet on all floors with Hose Reel is provided.
6. 08 Hose reel of 100 feet on all outlets shall be provided
7. Fire Extinguisher of ABC -05 kg-12 Nos / Fire Buckets of suitable capacity / quantity is Provided.
8. Fire Aarm system Nos. 01 & Manual call point Nos. 06 & Hooter Nos. 06 & Smoke Detector 30 Nos are provided
8. Fire Fighting system Testing each six month as Juluy to January Authorised fire Agency certified as per the fire act 2006.

Sudalcare

VICE PRINCIPAL
JITO DELHI PUBLIC SCHOOL,
AURANGABAD

JITO-DELHI PUBLIC SCHOOL, AURANGABAD


PRO-VICE CHAIRMAN

9. Fire Noc is renewed each year.

As per BMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006. Fire NOC Renewed is issued to the Principal, Jito School The Joint Venture, The Delhi Public School Society, Gut No. 59/P, Shernapur Ta & Dist. Aurangabad.



23-3-2022
Chief Fire Officer
Fire Brigade
Municipal Corporation Aurangabad

Copy to:- A.D.T.P AMC, Aurangabad.

JITO-DELHI PUBLIC SCHOOL, AURANGABAD



PRO-VICE CHAIRMAN

Shakare

VICE PRINCIPAL
JITO DELHI PUBLIC SCHOOL,
AURANGABAD

JITO-DELHI PUBLIC SCHOOL, AURANGABAD

PRO-VICE CHAIRMAN

VICE PRINCIPAL
JITO DELHI PUBLIC SCHOOL,
AURANGABAD